

Model: 6PLV/xxx/DIR

Where xxx means 824-965 which indicates CRI and color temperature



ELECTRONIC BALLAST COMPATIBILITY

Brand	Model	Compatibility
Philips - Advance	ICF-2S13-M1-BS-QS	OK
	ICF-2S18-M1-BS-QS	OK
	ICF-2S18-H1-LD	OK*
Sylvania	QTP 1/2x13CF/UNV DM	OK
Hatch	HC213PS/UV/D	OK
Triad/Universal Lighting	C213UNVBES	OK
	C213UNVME	OK
	C218UNVME	OK
Howard Lighting	EP2/13CF/MV/2	OK
	EP2/18CF/MV/2	OK
Fulham	RHA-UNV-213-C	OK**

WARNING DO NOT INSTALL LAMPS WITH THE FOLLOWING BALLASTS. DO NOT INSTALL LAMPS WITH BALLASTS NOT ON THIS LIST UNTIL COMPATIBILITY IS CONFIRMED WITH OUR TECHNICAL TEAM. Some older ballast versions can cause over heating and damage to lamp and fixture. In case of doubt about compatibility, please contact us: techsupport@greengreative.com

Philips - Advance	REB-2S26M-BS	X
	H-2B13-TP-BLS	X
Sylvania	QTP 2x26CF/UNV QS	X
	QTP 2x26CF/UNV BS	X
	QTP 2x26CF/UNV TS	X
	QTP 2x26/32/42CF/UNV BM	X
	QTP 2x26/32/42CF/UNV TM	X
	QTP 1/2x18CF/UNV TS	X
	QTP 1/2xCF/UNV BM	X
QTP 1/2xCF/UNV TM	X	

ELECTRONIC BALLAST COMPATIBILITY

Brand	Model	Compatibility
Sylvania	M1/2-CF-B-M-UNIV	X
	M2-CF-18-Q-S-277V	X
	QT2x32/277V IS-SC	X
Universal - Triad	CBT213L-120S	X
Antron	CSD-132PBM	X
Fulham	LH1-277-L	X
	SC-120-113-CFL	X
AC Electronics	CSD-332PBM	X
	EST-A40PS	X
Standard	31003STD E1321-UV-S	X
Topaz	B2642UNV/ME-TPZ	X
Watran	DBC218MVRSN	X
Motorola	M1-CF-42-B-S-120	X
Robertson	RED2L10-277	X
Hatch	FR1800	X
Energy Savings	ES-1-CFH-42/32/26-UNV-C	X

* Not compatible with older versions of this ballast

** Compatible in 2-lamp installations only

*** GREEN CREATIVE has provided this ballast compatibility chart for guidance when selecting a ballast and lamp combination. Lamps were tested for compatibility with the above listed electronic ballasts. Ballasts that do not appear on the chart might still be compatible but have not been tested. All testing has been performed with a stable main supply. The quality of the local main, existing installation and wiring, as well as different manufacturer versions of the above ballasts may affect lamp performance. Since no assurance can be provided regarding these factors, it is a general recommendation to perform a test on-site prior to installing the LED lamps.